



EGU HV LABORATORY

Accredited testing laboratory No.: 1029

Accredited by Czech Accreditation Institute
according to ČSN EN ISO/IEC 17025:2018

TEST REPORT No.: 11788/U/21



CUSTOMER:

Jiangsu Shemar Electric Co., Ltd.
66 Haiwei Road
226 017 Nantong, Jiangsu
China

TEST OBJECT:

69 kV Composite insulator

TYPE SPECIFICATION:


SML 133 kN

TEST STANDARDS:

ANSI C29.12-2020, ANSI C29.11-2020


Michal Novotný
Test engineer


Marek Brosch
Head of
EGU HV LABORATORY


Jan Lachman, Ph.D.
Director of
EGU - HV Laboratory a. s.

Test report is confidential and must not be circulated or transferred to any third party without written approval of the customer. Test results relate only to the tests given in presented report and do not substitute any other documents. The report shall not be reproduced except in full without written approval of the testing laboratory. The EGU HV Laboratory doesn't perform sampling as test objects and relevant data are supplied to the EGU HV Laboratory by a customer. All tests were performed by EGU HV Laboratory at its registered office address if not specified else in this test report. The results apply to the sample as received. EGU HV Laboratory doesn't accept any kind of information provided by a customer that could affect validity of test results.

TEST REPORT**No.: 11788/U/21****TEST OBJECT:** 69 kV Composite insulator**TYPE SPECIFICATION:** SML 133 kN**DRAWING No.:** 21SM510755 Rev. A**MANUFACTURER:** Jiangsu Shemar Electric Co., Ltd.**DATE OF DELIVERY:** 2021-12-09**DATE OF TESTS:** From 2021-12-16 till 2022-03-15**ORDER No.:** Contract 23/21**TESTS WITNESSED BY:** N/A**ANNEX:** Testpolymer EU, test report 59/2022/EN

TABLE OF CONTENTS

| | | |
|-------|---|----|
| 1 | TEST SUMMARY | 4 |
| 2 | TESTS PERFORMED | 5 |
| 2.1 | Tests on interfaces and connections of end fittings | 5 |
| 2.1.1 | Visual inspection and dimensional check | 5 |
| 2.1.2 | Sudden load release | 5 |
| 2.1.3 | Thermal-mechanical test | 5 |
| 2.1.4 | Water penetration test | 6 |
| 2.1.5 | Verification tests | 6 |
| 2.2 | Core time-load test | 10 |
| 2.2.1 | Test specimens | 10 |
| 2.2.2 | Determination of the average failing load of the core | 10 |
| 2.2.3 | Core time-load test | 11 |
| 2.3 | Tests on the core material | 12 |
| 2.3.1 | Dye penetration test | 12 |
| 2.3.2 | Water diffusion test | 12 |
| 2.4 | Housing tracking and erosion test | 14 |
| 2.4.1 | Test procedure | 14 |
| 2.4.2 | Test results | 16 |
| 2.5 | Flammability test ³⁾ | 17 |
| 3 | UNCERTAINTY OF MEASUREMENTS | 18 |
| 4 | PRODUCT DRAWING | 19 |
| 5 | GRAPHS AND RECORDS | 20 |
| 6 | TEST OBJECT AND TEST SETUP PHOTOS | 27 |

1 TEST SUMMARY

| Test title | Test standard | Test result |
|---|--|-------------|
| Tests of interface and connection of fittings | ANSI C29.12, clause 8.1 ANSI C29.11, clause 7.1 | Passed |
| Visual inspection and dimensional check | ANSI C29.11, clause 7.1.1.1 | Passed |
| Sudden load release | ANSI C29.11, clause 7.1.3 | Passed |
| Thermal mechanical test | ANSI C29.11, clause 7.1.4.1 | Passed |
| Water penetration test | ANSI C29.11, clause 7.1.5 | Passed |
| Verification test | ANSI C29.11, clause 7.1.6 | Passed |
| Linearly rising front chopped impulse voltage test | ANSI C29.11, clause 7.1.6.2 | Passed |
| Low-frequency dry flashover test | ANSI C29.11, clause 7.1.6.3 | Passed |
| Core time-load test | ANSI C29.12, clause 8.2 ANSI C29.11, clause 7.2 | Passed |
| Determination of the average failing load of the core | ANSI C29.11, clause 7.2.1.2 | Passed |
| Core time – load test | ANSI C29.11, clause 7.2.1.3 | Passed |
| Tests on the core material | ANSI C29.12, clause 8.4 | Passed |
| Dye penetration test | ANSI C29.12, clause 8.4.1 ANSI C29.11, clause 7.4.1 | Passed |
| Water diffusion test | ANSI C29.12, clause 8.4.2 ANSI C29.11, clause 7.4.2 | Passed |
| Housing tracking and erosion test | ANSI C29.12, clause 8.3 ANSI C29.11, clause 7.3 | Passed |
| Flammability test ³⁾ (see TestpolymerEU test report 59/2022/EN) | ANSI C29.12, clause 8.5 ANSI C29.11, clause 7.5 | Passed |

Note:

³⁾ The test was done in an external accredited laboratory.

2 TESTS PERFORMED

2.1 Tests on interfaces and connections of end fittings

The test was carried out according to ANSI C29.12, clause 8.1 & ANSI C29.11, clause 7.1.

2.1.1 Visual inspection and dimensional check

Test specimens

Test was carried out according to ANSI C29.11, clause 7.1.1. The test was performed on composite insulator samples No.: 1, 2, 3 and 4 REF.

No. 1, serial No. 2111150059,

No. 2, serial No. 2111150052,

No. 3, serial No. 2111150063.

No. 4 REF, serial No. 2111150065.

The insulators were examined visually and their dimensions were checked against the manufacturer's drawing (see Figure 1).

Testing and measuring equipment

tape measure 5 m, CXS, PM-241

slide gauge 150 mm, Kinex CZ, serial No. KN2038

Evaluation:

Insulators were without damage and dimensions conform to the drawing.

2.1.2 Sudden load release

Test date: 2022-03-03

Tests were carried out according to ANSI C29.11, clause 7.1.3.

This test was performed on insulators No. 1, 2 and 3 at temperatures of $-20\text{ }^{\circ}\text{C}$ to $-25\text{ }^{\circ}\text{C}$. Each of tested insulators was subjected to five sudden load releases from a tensile load of 39,9 kN (30 % of SML, SML=133 kN) and held for minimum 15 seconds.

Testing and measuring equipment

thermal mechanical chamber Horkan Klima, inventory No. 1089

loading measuring system Format 1, type EGU – 2V, serial No. Z201128288

digital thermometer - datalogger, Comet system, serial No. 18931703

2.1.3 Thermal-mechanical test

Date of test: from 2022-03-03 till 2022-03-07

Tests were carried out according to ANSI C29.11, clause 7.1.4.1.

Three insulators No. 1, 2 and 3 were subjected to a mechanical load of 6,7 kN (5 % of SML, SML=133 kN) for the duration one minute, the reference total length was measured. Measured values are shown in Table 1.

Three insulators No. 1, 2 and 3 were subjected to a mechanical load of 66,5 kN (100% of RTL). Each insulator was subjected to four 24-hour cycles with one cooling period of $-35\text{ }^{\circ}\text{C} \pm 5\text{ }^{\circ}\text{C}$, followed by one heating period of $+50\text{ }^{\circ}\text{C} \pm 5\text{ }^{\circ}\text{C}$.

Records of measured temperatures and mechanical tension during the thermal-mechanical testing are given in Graphs 2, 3, 4 and 5. The test arrangement during the thermal-mechanical test on the insulator is shown in Figure 2.

Testing and measuring equipment:

thermal mechanical chamber LaborTech, type Creep test 6.500.C3, serial No. ZA/2018/51
 digital thermometer - datalogger, Comet system, serial No. 18931703
 thermal mechanical chamber Horkan Klima, inventory No. 1089
 loading measuring system Format 1, type EGU – 2V, serial No. Z201128288
 digital thermometer - datalogger, Comet system, serial No. 19270819
 tape measure 5 m, CXS, PM-241

Table 1

| Insulator No. | 1 | 2 | 3 |
|--|----------|----------|----------|
| Reference length at both places before test (mm) | 1 175 | 1 170 | 1 173 |
| Reference length at both places after test (mm) | 1 175 | 1 170 | 1 173 |

2.1.4 Water penetration test

Test date: from 2022-03-08 till 2022-03-10

Three tested insulators No. 1, 2, 3 were immersed according to ANSI C29.11, clause 7.1.5 for 42 hours in boiling deionized water with 0,1 % by weight of NaCl (see Figure 3).

At the end of boiling, the insulators remained immersed until the water cooled to approx. 50 °C and maintained at this temperature until the verification tests started.

Testing and measuring equipment

Heating water vessel AKV2, inventory No. 2420

2.1.5 Verification tests

Test date: 2022-03-11

Tests were carried out according to ANSI C29.11, clause 7.1.6.

2.1.5.1 Visual examination

Insulators were inspected visually.

Evaluation:

No cracks were observed.

2.1.5.2 Lineary rising front chopped impulse voltage test

Test was carried out according to ANSI C29.11, clause 7.1.6.2.

Atmospheric conditions:

| | |
|-------------------|-----------------------|
| air pressure | 99,6 kPa (29,41 inHg) |
| air temperature | 18,2 °C (64,8 °F) |
| relative humidity | 26,8 % |


Insulators No. 1, 2, 3 were tested. Insulators were divided by electrode on sections. 25 impulses of both polarities with a steepness of at least 1000 kV/ μ s were applied on each section:

- the original upper metal fitting and an electrode made of a copper strip 20 mm wide and less than 1 mm thick (upper section),
- electrode made of a copper strip 20 mm wide and less than 1 mm thick and an original bottom metal fitting (bottom section).

The test arrangement and the flashover on the insulator are shown in Figure 4.

The wave shape of the test impulse is given in Graph 1.

Testing and measuring equipment



impulse generator TuR Dresden 750 kV, 30 kJ

R_{d1}/R_{d2} - resistive divider Haefely, 800 kV, serial No. 554333

measuring system Haefely Trench, type HiAS 743, serial No. 175247

measuring system for atmospheric conditions Comet, serial No. 10910247

tape measure 7,5 m, Assist, PM-242

Evaluation:

No punctures of the sheds or the core were occurred.

2.1.5.3 Low-frequency dry flashover voltage test

Atmospheric conditions:

| | |
|-------------------|-----------------------|
| air pressure | 99,6 kPa (29,41 inHg) |
| air temperature | 15,3 °C (59,5 °F) |
| relative humidity | 26,6 % |

Testing and measuring equipment

Regulation transformer TuR Dresden 6/0-6kV, 3 200 kVA, serial No. 870786
 test transformer TuR Dresden, 500 kV/3 000 kVA, serial No. 870785
 divider MCF 600, serial No. 863705
 universal voltmeter Haefely DMI 551, serial No. 187833
 digital stop-watch Fastime, PM-251
 measuring system for atmospheric conditions COMET, serial No. 10910247
 digital thermometer Fluke 54II, serial No. 3910029WS + probe 80PK-27
 tape measure 7,5 m, Assist, PM-242

This test consisted of the following two tests:

a) Low-frequency dry flashover voltage test

Samples No. 1, 2, 3 and 4 REF (as a reference sample) were tested, see Figure 4. The average of five flashover voltages on each insulator was corrected to normal standard atmospheric conditions in accordance with ANSI C29.11, clause 8.2.1.5. The flashover voltage was obtained by increasing the voltage linearly from zero within one minute.

The test arrangement and the flashover of the insulator are shown in Figure 5.

The value of reference flashover voltage was obtained from insulator 4 REF.

The average value of the flashover voltages of insulators No. 1, 2, 3 shall be greater than or equal to 90 % of flashover voltage of the reference insulator 4 REF. Table 2 and 3 display the results of these measurements.

Table 2

| Insulator No. | Uncorrected flashover values (kV) | | | | | Uncorrected flashover average (kV) | Correction factors | Corrected reference flashover voltage (kV) |
|---|-----------------------------------|-----|-----|-----|-----|------------------------------------|--------------------------------|--|
| 4 REF | 364 | 371 | 364 | 369 | 359 | 365 | $K_d = 1,016$ $K_h = 1,148$ | 412 |
| 90 % of corrected reference flashover voltage = 371 kV | | | | | | | | |
| 80 % of uncorrected reference flashover voltage = 292 kV | | | | | | | | |

Table 3

| Insulator No. | Uncorrected flashovers values (kV) | | | | | Uncorrected flashover average (kV) | Correction factors | Corrected flashover average (kV) |
|---------------|------------------------------------|-----|-----|-----|-----|------------------------------------|--------------------------------|----------------------------------|
| 1 | 368 | 360 | 365 | 360 | 364 | 363 | $K_d = 1,016$ $K_h = 1,148$ | 410 |
| 2 | 365 | 367 | 355 | 367 | 359 | 363 | $K_d = 1,016$ $K_h = 1,148$ | 410 |
| 3 | 358 | 364 | 364 | 369 | 363 | 362 | $K_d = 1,016$ $K_h = 1,148$ | 409 |

All measured voltages are corrected for the standard reference atmosphere according to ANSI C29.11, clause 8.2.1.5.

K_h humidity correction factor,
 K_d air density correction factor.

Evaluation:

Average corrected flashover voltage values of insulators No. 1, 2, 3 exceed 90 % of the reference flashover voltage.

b) Low-frequency dry withstand test

Each of tested insulators No. 1, 2, 3 and 4 REF were individually subjected for 30 minutes to 80 % of the average reference flashover voltage. The requirement is that during this test no puncture of the insulator shall occur. The temperature rise ΔT of the shank measured immediately after the test at five locations distributed approximately evenly along the length of the insulator shall be not more than 20 °C above ambient. The results are shown in Table 4.

Table 4

| Insulator No. | Test voltage (kV) | Result | ΔT (°C) | Result |
|---------------|-------------------|-------------|-----------------|--------|
| 1 | 292 | no puncture | < 20 | passed |
| 2 | 292 | no puncture | < 20 | passed |
| 3 | 292 | no puncture | < 20 | passed |
| 4 REF | 292 | no puncture | < 20 | passed |

Evaluation:

No puncture was occurred and the temperature rise of the insulator shank was not more than 20 °C above the ambient temperature.

Statements of conformity:

69 kV Composite insulator, SML 133 kN, drawing No. 21SM510755 Rev. A, passed the the test according to requirements given in ANSI C29.12, clause 8.1 & ANSI C29.11, clause 7.1.

2.2 Core time-load test

2.2.1 Test specimens

Test was carried out according to ANSI C29.12, clause 8.2 & ANSI C29.11, clause 7.2. The six insulators were examined visually. The tests were performed on composite tension insulators samples No. 1, 2, 3, 4, 5 and 6.

No. 1, serial No. 2111150058,

No. 2, serial No. 2111150051,

No. 3, serial No. 2111150083.

No. 4, serial No. 2111150067,

No. 5, serial No. 2111150060,

No. 6, serial No. 2111150066.

Testing and measuring equipment:

slide gauge 300 mm, Kinex CZ, serial No. 2441/05

tape measure 5 m, CXS, PM-241

Evaluation:

Insulators were without damage and dimensions conform to the drawing.

2.2.2 Determination of the average failing load of the core

Test date: from 2022-03-03

Test was carried out according to ANSI C29.11, clause 7.2.1.2. Three insulators No. 1, 2 and 3 were subjected to tensile load applied between couplings. The tensile load was increased rapidly but smoothly from zero to approximately 100 kN (75 % SML) and then gradually increased in a time between 30 s to 90 s until breakage of the core or complete pull-out occurs (see Figure 6, 7 and 8). The average value of the three failing loads was calculated.

Records of measured mechanical loading during the mechanical failing test are given in Graphs 6, 7 and 8.

The samples after mechanical failing load test are shown in Figure 6, 7, 8 and 9.

Testing and measuring equipment

Hydraulic loading machine LabTest 5.600SP1, serial No. 15/12

Test results

The results are shown in Table 5.

Table 5

| Test sample No. | Type of failure | Composite insulator failing load (kN) |
|---------------------------------------|---|---------------------------------------|
| 1 | Pull out of the core from the end fitting | 211,7 |
| 2 | Pull out of the core from the end fitting | 205,7 |
| 3 | Pull out of the core from the end fitting | 196,3 |
| Average value of the failing load | | 204,6 |
| 60 % of average value of failing load | | 122,8 |

2.2.3 Core time-load test

Test date: from 2022-03-07 till 2022-03-15

Test was carried out according to ANSI C29.11, clause 7.2.1.3. Three insulators No. 4, 5 and 6 were subjected to a tensile load applied between couplings. The tensile load was increased rapidly but smoothly, from zero up to 122,8 kN (60 % of average failing load) and then maintained at this value for 96 hours.

Record of mechanical loading applied during mechanical 96 hours tests are given in Graphs 9, 10 and 11.

Test samples during the mechanical 96 hours load test are shown in Figure 10.

Testing and measuring equipment

Thermal-mechanical chamber, inventory No. 1089

Loading system Format 1, type EGU – 2V, serial No. Z201128288

Thermal-mechanical chamber, inventory No. 2237

Loading system Format 1, type EGU – 1V, serial No. Z201128287

Evaluation:

No failure (breakage or complete pull-out of the core or fracture of the metal fittings) occurred during 96 h test on insulators No. 4, 5 and 6.

Statement of conformity:

69 kV Composite insulator, SML 133 kN, drawing No. 21SM510755 Rev. A, passed the test according to requirements given in ANSI C29.12, clause 8.2 & ANSI C29.11, clause 7.2.

2.3 Tests on the core material

2.3.1 Dye penetration test

Test date: 2022-01-03

The test was carried out according ANSI C29.12, clause 8.4.1 & ANSI C29.11, clause 7.4.1.

Test specimens

Ten test samples of core rod diameter Ø24 mm, 10 mm in length were prepared and delivered by customer.

Test procedure

Test specimens were placed (with fibres in vertical position) on a layer of glass balls (diameter 2 mm) in a glass vessel. A dye (1 % methyl alcohol solution of Astrazon BR 200) was poured into the vessel, with its level 2,5 mm above the glass balls, see Figure 11. The time taken for the dye to rise (by capillary action) through the specimens was measured.

Testing and measuring equipment:

digital stop-watch Olympia PM-172

slide gauge 150 mm, Kinex CZ, serial No. KN2038

Evaluation:

There were no traces of dye penetration through the insulator core recorded during 15 minutes.

Statement of conformity:

Core rod diameter Ø24 mm, passed the test according to requirements given in ANSI C29.12, clause 8.4.1 & ANSI C29.11, clause 7.4.1.

2.3.2 Water diffusion test

Test date: from 2022-01-03 till 2022-01-07.

The test was carried out according to ANSI C29.12, clause 8.4.2 and ANSI C29.11, clause 7.4.2.

Test specimens

Six test samples of core rod diameter Ø24 mm, 30 mm in length were prepared and delivered by customer.

Pre-stressing

The surfaces of the specimens were cleaned with isopropyl-alcohol and filter-paper immediately before the boiling. The specimens were boiled in a glass container for 100 hours in deionised water with 0,1 % by weight of NaCl.

After boiling, the specimens were removed from the glass container and placed in another glass container filled with tap water at ambient temperature for 15 minutes. The voltage test described in the following clause was carried out within the next three hours.

Voltage test

Immediately before the voltage test the specimens were removed from the glass container and their surfaces dried with filter paper.

Each specimen was placed between the test electrodes. The test voltage was increased at rate of approximately 1 kV/sec up to 12 kV, kept at this level for one minute and then decreased to zero, see Figures 12 and 13.

Testing and measuring equipment

voltage source HVI 30 kV, type HPA-305FC1, serial No. 006 + Analog panel meters model 553

slide gauge 150 mm, Kinex CZ, serial No. KN2038

Multimeter UT60E, serial No. 110055936 + shunt PM-160

Digital stop-watch Fastime, PM-251

Measuring cylinder, type 1000 ml, i.n. 2/044/11

Heating water vessel, type LTHS 4000, serial No. 18102

Weight Sartorius, type S210P, serial No. 39010002

Table 6 The results of the leakage current measurements

| Specimen No. | Test voltage (kV) | Leakage current (μ A) | Test duration (sec) | Result |
|--------------|-------------------|----------------------------|---------------------|--------|
| 1 | 12,0 | 30,2 | 60 | passed |
| 2 | 12,0 | 31,1 | 60 | passed |
| 3 | 12,0 | 30,4 | 60 | passed |
| 4 | 12,0 | 30,3 | 60 | passed |
| 5 | 12,0 | 30,0 | 60 | passed |
| 6 | 12,0 | 30,5 | 60 | passed |

Evaluation:

No puncture or external flashover occurred. The leakage current did not exceed maximum allowable current of 1 mA (r.m.s.).

Statement of conformity:

Core rod diameter \varnothing 24 mm, passed the test according to requirements given in ANSI C29.12, clause 8.4.2 & ANSI C29.11, clause 7.4.2.

2.4 Housing tracking and erosion test

Specification of silicone rubber

Manufacturer: Jiangsu Shemar Electric Co., Ltd.

Address: No. 66, Haiwei Road, Sutong Science and Technology Industrial Park, Nantong City, Jiangsu 226017, China

Type: HTV silicone rubber

Color: Light gray

Butch number: N/A

The silicone rubber specification was provided by the customer.

2.4.1 Test procedure

Test was carried out according to ANSI C29.12, clause 8.3 and ANSI C29.11, clause 7.3.

Test specimens

Two samples of a composite insulator 69 kV with reduced length, were subjected to a salt fog test in accordance with ANSI C29.11, clause 7.3.1. The test was performed on the insulator in horizontal position (Sample No. 2) and vertical position (Sample No. 1).

Table 7

| | | |
|---------------------|----------------------------|----------------------------------|
| Composite insulator | Type | 69 kV |
| | Manufacturer | Jiangsu Shemar Electric Co., Ltd |
| | Measured creepage distance | 631 mm |
| | Measured arcing distance | 276 mm |
| | Diameter of the shank | 35 mm |
| | Test sample No.1 | Serial No. 211115056 |
| | Test sample No.2 | Serial No. 211115074 |

Table 8

| | |
|--|--|
| Test voltage: | 18,2 kV (measured creepage distance 631 mm divided by 34,6) |
| Beginning of the test: | 2021-12-16 |
| End of the test: | 2022-01-27 |
| Starting salinity: | $8 \pm 0,4 \text{ kg/m}^3$ |
| Finishing salinity: | $8 \pm 0,4 \text{ kg/m}^3$ |
| Intensity of the precipitation of the salt fog test: | between 1,5 and 2,0 ml/h |
| Test duration: | 1015,5 hours |
| Temperature: | $20^\circ\text{C} \pm 5 \text{ K}$ |
| The average collect of precipitation | 1,84 ml/h |

Test chamber

The test chamber was prepared according to ANSI C29.11, clause 7.3.2.

Test was performed in a moisture-sealed corrosion-proof chamber not exceeding 15 m³ (530 ft³). The two sprayer of constant spraying capacity were mounted close to the bottom of the test chamber and spray upwards towards the roof of the test chamber. A solution of NaCl and de-ionized water was supplied to the sprayer.

Sample mounting

Test specimens were cleaned with de-ionized water before starting the test. One test specimen was tested mounted horizontally and the second test specimen was mounted vertically. There was a clearance of at least 200 mm between the roof of the chamber and a test specimen a clearance of at least 100 mm between the side walls of the chamber and a test specimen and at least 400 mm between parallel test specimens.

Fog calibration

The fog calibration was done according to ANSI C29.11, clause 7.3.2.2.

Before commencing the test two collecting receptacles with a collection area of 7085 mm² and a height of 100 mm were placed close to the position of the ends of the test objects. They collected between 1,5 ml and 2,0 ml of precipitation per hour (corrected to 8000 mm² collecting area) averaged over a minimum period of 16 hours. The flow rate was checked at least every 100 hours. Interruption times are not to be counted as test time.

Test voltage

The test voltage was adjusted according to ANSI C29.11, clause 7.3.3.3.1.

The test circuit when loaded with a continuous resistive current of 250 mA (r.m.s.) during 1 sec on the high voltage side shall experience a maximum voltage drop of 5 %.

The protection level of the tripping device was set at 1 A (r.m.s.).

Test conditions

The test conditions were adjusted according to ANSI C29.11, clause 7.3.3 Duration of the test: 1015,5 h. Weekly interruptions of the test for inspection purposes did not exceed 1 h. Numbers of flashovers and trip outs, when occurred, were recorded.

Temperature

The ambiente temperature within the chamber was 20 °C ±5 K.

Testing and measuring equipment

Test transformer Třebíč,, serial No. 6022

Voltage divider ABB, type TDC7, 35/0,1 kV, serial No. VLT52111022698

Measuring system Dewe-rack + USB converter 6341, serial No. 52150637/1890C82

Conductivity meter, WTW Cond 3310, serial No. 10410891

Measuring system for atmospheric conditions COMET, serial No. 16910046

Measuring cylinder 250 ml, PM-256

Stop watch Olympia, PM-172

Tape measure, CXS 5 m, PM-241

slide gauge 150 mm, Kinex, serial No. KN2038

measuring system for atmospheric conditions Comet, serial No. 16910046

2.4.2 Test results

Table 9

| Sample No. | Position | Number of flashovers | Visual examination |
|------------|------------|----------------------|---|
| 2 | horizontal | 0 | no erosion occurred, no tracking occurred no puncture of shed, housing or interface occurred |
| 1 | vertical | 0 | no erosion occurred, no tracking occurred no puncture of shed, housing or interface occurred |

The pictures of test samples before starting and after end of the test are given in Figure 14, 15, 16, 17 and 18.

Table 10 Test dates of collected precipitation

| Date of inspection | Time of period (h) | Average collect (ml/h) | Interrupt time for checked of precipitation rate (min) |
|--------------------|--------------------|------------------------|--|
| 16.12 | Start | | |
| 20.12. | 96 | 1,85 | 15 |
| 23.12. | 72,75 | 1,82 | 15 |
| 27.12. | 97,75 | 1,89 | 15 |
| 31.12. | 92,75 | 1,83 | 15 |
| 3.1. | 73,75 | 1,88 | 15 |
| 7.1. | 95,75 | 1,85 | 15 |
| 10.1. | 71 | 1,91 | 15 |
| 14.1. | 95 | 1,84 | 15 |
| 17.1. | 73,25 | 1,81 | 15 |
| 21.1. | 98,5 | 1,83 | 15 |
| 24.1. | 67,75 | 1,79 | 15 |
| 27.1. | 79 | 1,79 | End of the tst |

Evaluation:

No erosion, no tracking and puncture of shed, housing or interface occurred on horizontal and vertical composite insulator.

Statement of conformity:

69 kV Composite insulator, SML 133 kN, drawing No. 21SM510755 Rev. A, passed the test according to requirements given in ANSI C29.12, clause 8.3 & ANSI C29.11, clause 7.3.

2.5 Flammability test ³⁾

The test was performed according to ANSI C29.12, clause 8.5 & ANSI C29.11, clause 7.5.

The test was performed by accredited test Testpolymer EU as per report No. 59/2022/EN.

The silicone rubber samples of required dimensions were provided by the customer.

Evaluation:

The silicone material HTV, passed specification V0 and HB.

Statement of conformity:


Test specimens of HTV silicone rubber passed the test according to requirements given in ANSI C29.12, clause 8.5 & ANSI C29.11, clause 7.5.

3 UNCERTAINTY OF MEASUREMENTS


| QUANTITY | UNCERTAINTY (k=2) | |
|---|----------------------|----------------|
| | U_m T_1 | |
| Steep front impulse voltage | | 2,2 % 6,5 % |
| Power-frequency voltage | | 1,7 % |
| Power-frequency voltage (water diffusion test) | | 0,3 kV |
| Power-frequency voltage (salt fog) | | 1,0 % |
| Mechanical load (CreepTest) | | 1,0 % |
| Mechanical load (LabTest) | | 1,0 % |
| Mechanical load (Horkan Klima) | | 1,3 % |
| Temperature (thermal-mechanical chamber) | | 3,0 % |
| Temperature (Fluke) | | 7,5 % |
| Length (2-150 mm) | | 0,4 % |
| Length (2-300 mm) | | 0,5 % |
| Length (10-5 000 mm) | | 1,6 % |
| Length (10-7 500 mm) | | 1,6 % |
| Temperature | | 4,0 % |
| Air pressure | | 0,5 % |
| Relative humidity | | 6,3 % |
| Time | | 0,7 % |
| Body of water (20 – 250 ml) | | 1,0 ml |
| Body of water (200 – 1000 ml) | | 10,0 ml |
| Weight | | 0,9 % |
| Conductivity (0,1 μ S/cm – 1000 mS/cm) | | 5,0 % |
| Power-frequency leakage current (water diffusion test) | | 1,3 % |

The reported expanded uncertainty of measurement is stated as the standard uncertainty of measurement multiplied by the coverage factor $k = 2$, which for a Normal (Gaussian) distribution corresponds to a coverage probability of approximately 95 %. Details related to the statement of conformity when applied are given in a price quotation submitted to a customer before the testing and on the website of the laboratory.

5 GRAPHS AND RECORDS




No. 7
Upk max: 552.098 kV
Upk min: -37.452 kV
T1 : 528.308 ns
SR : 1.047 MV/us




No. 2
Upk max: -593.239 kV
Upk min: 49.764 kV
T1 : 575.473 ns
SR : -1.033 MV/us


Graph 1
Representative wave shape of lineary rising front chopped impulse




Graph 2
Record of temperature during thermal-mechanical cycles, test samples No. 1 and 2




Graph 3
Record of temperature during thermal-mechanical cycles, test sample No. 3




Graph 4
Record of tensile laod during thermal-mechanical cycles, test samples No. 1 and 2




Graph 5
Record of tensile laod during thermal-mechanical cycles, test sample No. 3




Graph 6
Record of mechanical loading test, sample No. 1




Graph 7
Record of mechanical loading test, sample No. 2




Graph 8
Record of mechanical loading test, sample No. 3



Graph 9
Record of 96 hours mechanical loading test, sample No. 4



Graph 10
Record of 96 hours mechanical loading test, sample No. 5



Graph 11
Record of 96 hours mechanical loading test, sample No. 6

6 TEST OBJECT AND TEST SETUP PHOTOS



Figure 2
Test samples No. 1, 2 and 3, during thermal – mechanical test



Figure 3
Test samples No. 1, 2 and 3, before watter penetration test




Figure 4
Test sample, during the lineary rising front chopped impulse voltage test




Figure 5
Test sample, during the low-frequency dry flashover voltage test




Figure 6
Test sample No. 1, after the mechanical failing load test




Figure 7
Test sample No. 2, after the mechanical failing load test




Figure 8
Test sample No. 3, after the mechanical failing load test




Figure 9
Test samples No. 1, 2 and 3, after the mechanical failing load test



Figure 10

Test samples No. 4, 5 and 6, during the verification of the 96 hours mechanical load test, test




Figure 11

Test specimens after the dye penetration test




Figure 12
Test specimens during the voltage test – water diffusion test



Figure 13
Test specimens after the voltage test – water diffusion test




Figure 14
Test sample No. 2, horizontal position, before the housing tracking and erosion test



Figure 15
Test sample No. 2, horizontal position, after the housing tracking and erosion test



Figure 16

Test sample No. 1, vertical position, before and after the housing tracking and erosion test



Figure 17

Test sample No. 1, vertical sample after the housing tracking and erosion test



Figure 18
Test sample No. 1, vertical sample after the housing tracking and erosion test

- end of test report -



EGU HV LABORATORY

Accredited testing laboratory No.: 1029
Accredited by Czech Accreditation Institute
according to ČSN EN ISO/IEC 17025:2018

TEST REPORT No.: 11788/M/21

CUSTOMER:

Jiangsu Shemar Electric Co., Ltd.
66 Haiwei Road
226 017 Nantong, Jiangsu
China



TEST OBJECT:

69 kV Composite insulator


TYPE SPECIFICATION: SML 133 kN

TEST STANDARDS:

ANSI C29.12-2020, ANSI C29.11-2020,
NEMA 107:2016, IEEE Std 4:2013


Michal Novotný
Test engineer


Marek Brosch
Head of
EGU HV LABORATORY


Jan Lachman, Ph.D.
Director of
EGU - HV Laboratory a. s.

Test report is confidential and must not be circulated or transferred to any third party without written approval of the customer. Test results relate only to the tests given in presented report and do not substitute any other documents. The report shall not be reproduced except in full without written approval of the testing laboratory. EGU HV Laboratory doesn't perform sampling as test objects and relevant data are supplied to EGU HV Laboratory by a customer. All tests were performed by EGU HV Laboratory at its registered office address if not specified else in this test report. The results apply to the sample as received. EGU HV Laboratory doesn't accept any kind of information provided by a customer that could affect validity of test results.

TEST REPORT**No.: 11788/M/21****TEST OBJECT:** 69 kV Composite insulator**TYPE SPECIFICATION:** SML 133 kN**DRAWING No.:** 21SM510755 Rev. A**MANUFACTURER:** Jiangsu Shemar Electric Co., Ltd.**DATE OF DELIVERY:** 2021-12-09**DATE OF TESTS:** From 2022-02-28 till 2022-03-07**ORDER No.:** Contract 23/21**TESTS WITNESSED BY:** N/A

TABLE OF CONTENTS

| | | |
|-------|---|----|
| 1 | TEST SUMMARY | 4 |
| 2 | TESTS PERFORMED..... | 5 |
| 2.1 | Radio-Influence Voltage (RIV) | 5 |
| 2.1.1 | Test procedure | 5 |
| 2.1.2 | Test results..... | 6 |
| 2.2 | Critical Impulse Flashover Tests-Positive and Negative..... | 7 |
| 2.2.1 | Test procedure | 7 |
| 2.2.2 | Test results..... | 8 |
| 2.3 | Low-Frequency Wet Flashover Test | 9 |
| 2.3.1 | Test procedure | 9 |
| 2.3.2 | Test results..... | 10 |
| 2.4 | Low-Frequency Dry Flashover Test..... | 11 |
| 2.4.1 | Test procedure | 11 |
| 2.4.2 | Test results..... | 12 |
| 3 | LIST OF SYMBOLS | 13 |
| 4 | UNCERTAINTY OF MEASUREMENTS | 14 |
| 5 | PRODUCT DRAWING..... | 15 |
| 6 | TEST SETUP PHOTOS | 16 |
| 7 | GRAPHS..... | 19 |

1 TEST SUMMARY

| Test title | Test standards | Test result |
|--|-------------------------|-------------|
| Radio-Influence Voltage (RIV) | ANSI C29.12, clause 9.4 | Passed |
| Critical Impulse Flashover Tests – Positive and Negative | ANSI C29.12, clause 9.3 | Passed |
| Low-Frequency Wet Flashover test | ANSI C29.12, clause 9.2 | Passed |
| Low-Frequency Dry Flashover test | ANSI C29.12, clause 9.1 | Passed |

2 TESTS PERFORMED

2.1 Radio-Influence Voltage (RIV)

2.1.1 Test procedure

Date of test: 2022-02-28

The test was carried out according to ANSI C29.12, clause 9.4, ANSI C29.11, clause 8.2.8 and customer requirements. The test was performed on one composite insulator assembly, including grading ring, serial No. 2111150079.

Radio influence voltage RIV was measured according to NEMA 107. RIV (expressed in decibels relative to 1 μ V across 150 Ω) was measured at the frequency of 1,0 MHz in compliance with the circuit diagram in Figure 3-3a of NEMA 107, Section 3.

The circuit RIV factor was 0,42.

Measured RIV values are shown in Table 1.

The test arrangement was set up according to ANSI C29.11, clause 8.2.8.1 and customer requirements (see Figure 2). The single conductor was simulated using an aluminium tube of 14 m length and 30 mm diameter. Both ends of the tube were terminated with corona shielding spheres (screening electrode) with a diameter of 300 mm. Conductor was at a height of 4,15 m above the ground.

Testing and measuring equipment:

coupling capacitance, 1 000 pF, 800 kV, serial No. 11100108.10.1

measuring impedance Power Diagnostix, NEMA 150 Ω , type CIT4M/V8 μ 0/RIV, serial No. 12533

test transformer TuR Dresden 5,7/1 200 kV, 1 500 kVA

inductive regulator ČKD Praha 6/ 0 - 3 kV, 50 kVA

capacitive divider TuR Dresden 1 200 kV, 150 pF, type WMC 160/1200, serial No. 884470

universal voltmeter Haefely Trench, type DMI 551, serial No. 150505

RIV meter - measuring receiver Power Diagnostix, type RIV meter, serial No. 035

calibrator Power Diagnostix, type CAL3B, serial No. 3014

measuring system for atmospheric condition COMET, serial No. 10910247

digital stop-watch Kalenji, PM-259

measuring telescopic stick 5m, type BMI, serial No. 102

2.1.2 Test results

Table 1 Test results of the RIV test

| | | | |
|---------------------------|-----------------------|-----------------------|-----------------------|
| Rated voltage (kV) | 69 | | |
| Atm. conditions | | | |
| b (in Hg) | 29,65 | | |
| t (°F) | 60,4 | | |
| RH (%) | 33,1 | | |
| Test voltage (kV) | RIV ↓ (μV) | RIV ↑ (μV) | RIV ↓ (μV) |
| 145 | 25 119 | 31 623 | 31 623 |
| 135 | 10 000 | 10 000 | 10 000 |
| 125 | 22 | 22 | 22 |
| 120 | 22 | 22 | 22 |
| 110 | 22 | 22 | 22 |
| 100 | 22 | 22 | 22 |
| 61 | 22 | 22 | 22 |
| 56 | 22 | 22 | 22 |
| 51 | 22 | 22 | 22 |
| 46 | 22 | 22 | 22 |
| 41 | 22 | 22 | 22 |
| 36 | 22 | 22 | 22 |
| | | | |
| 0 | 22 | 22 | 22 |

Evaluation:

Measured RIV at 46 kV (115 % of nominal line – to – ground voltage, $1,15 \times 69/\sqrt{3} = 46$ kV) is lower than the specified value of 100 μV.

Statement of conformity:

69 kV Composite insulator, SML 133 kN, drawing No. 21SM510755 Rev. A, passed the test according to requirements given in ANSI C29.12, clause 9.4.

2.2 Critical Impulse Flashover Tests-Positive and Negative

2.2.1 Test procedure

Date of test: 2022-03-01

The test was carried out according to ANSI C29.12, clause 9.3 and ANSI C29.11, clause 8.2.6.

The test was performed on one composite insulator assembly, including grading ring, serial No. 2111150079.

The critical impulse voltage of positive and negative polarity was determined by the up and down method with 30 impulses according to ANSI C29.11, clause 8.2.6.4 and IEEE Std 4, clause 8.

All measured voltages were corrected to the standard reference atmospheric conditions according to ANSI C29.11, clause 8.2.6.6

The representative wave shape of the lightning impulse 1,2/50 μ s is given Graph 1.

The test arrangement was set up in compliance with ANSI C29.11, clause 8.2.6.2 and 8.1 (see Figure 4).

Testing and measuring devices:

impulse generator HighVolt IGL 180/1800G, serial No. IGG2295141

capacitive/resistive divider HighVolt, type MCR 0,4/2000-1000/1000 H391-41, serial No. MCR2295141/103732

measuring system High Volt, type HiRES S4D, serial No. HIGG2295141

tape measure 7,5 m, Assist, PM-242

measuring system for atmospheric condition COMET, serial No. 14900363

2.2.2 Test results

Table 2 Test results of the critical impulse flashover test – positive and negative

| Impulse polarity | + | – |
|--|------------|------------|
| Atm. conditions: | | |
| barometric pressure (in Hg) | 29,53 | 29,53 |
| temperature of air (°F) | 61,9 | 61,9 |
| relative humidity (%) | 35,2 | 35,2 |
| Correction factors: | | |
| air density correction factor K_d | 1,016 | 1,016 |
| humidity correction factor K_h | 1,101 | 1,087 |
| Critical impulse flashover voltage (kV) | 646 | 688 |
| Measured arcing distance: 980 mm | | |
| Drawing specified critical impulse flashover voltage: 628 kV | | |

Evaluation:

Critical impulse flashover value of positive and negative polarity was equal to or exceed 92% of the rated critical impulse flashover voltage specified by drawing 628 kV, i.e. 578 kV.

Statement of conformity:

69 kV Composite insulator, SML 133 kN, drawing No. 21SM510755 Rev. A, passed the test according to requirements given in ANSI C29.12, clause 9.3.

2.3 Low-Frequency Wet Flashover Test

2.3.1 Test procedure

Date of test: 2022-03-07

The test was carried out according to ANSI C29.12, clause 9.2 and ANSI C29.11, clause 8.2.2.

The test was performed on one composite insulator assembly, including grading ring, serial No. 2111150079.

Characteristics of the artificial rain and precipitation method was in accordance with the ANSI C29.11, clause 8.2.2.2.

The low-frequency wet flashover test was performed according to ANSI C29.11, clause 8.2.2.4 and 8.2.2.5. The flashover voltage was obtained by increasing the voltage continuously from zero up to flashover. The average of five flashovers was calculated.

All measured voltages were corrected to the standard reference atmospheric conditions according to ANSI C29.11, clause 8.2.2.6.

The test arrangement was set up in compliance with ANSI C29.11, clause 8.2.2.1 and 8.1 (see Figure 5).

Testing and measuring equipment:

synchronous generator BEZ Bratislava 6 kV, 1 300 kVA

test transformer TuR Dresden 5,7/1200 kV, 1500 kVA, serial No. 884469

capacitive divider TuR Dresden 1200 kV, 150 pF, type WMC 160/1200, serial No. 884470

universal voltmeter Haefely Trench, type DMI 551, serial No. 150505

measuring system for atmospheric conditions Comet, serial No. 10910247

tape measure 5 m, CXS, PM-241

digital stop-watch Kalenji PM-259

conductivity meter WTW Cond 3310, serial No. 10410891

plastic measuring cylinder 50ml, identification No. 1/153/14 & 2/153/14

2.3.2 Test results

Table 3 Test results of the low-frequency wet flashover test

| | |
|---|---------------------------------|
| Atm. conditions: barometric pressure (in Hg) temperature of air (°F) relative humidity (%) | 29,29 60,8 41,9 |
| Rain parameters: r. i. (mm/min) conductivity (μS/cm) | 5,0 192 |
| Correction factors: humidity correction factor K_h air density correction factor K_d Flashover voltage | 1,000 1,010 314 kV |
| Measured arcing distance: 980 mm | |
| Drawing specified low-frequency wet flashover voltage: 340 kV | |

Evaluation:

Low-frequency wet flashover value was equal to or exceed 90% of the rated wet flashover value specified by drawing 340 kV, i.e. 306 kV.

Statement of conformity:

69 kV Composite insulator, SML 133 kN, drawing No. 21SM510755 Rev. A, passed the test according to requirements given in ANSI C29.12, clause 9.2.

2.4 Low-Frequency Dry Flashover Test

2.4.1 Test procedure

Date of test: 2022-03-07

The test was carried out according to ANSI C29.12, clause 9.1 and ANSI C29.11, clause 8.2.1.

The test was performed on one composite insulator assembly, including grading ring, serial No. 2111150079.

The low-frequency dry flashover test was performed according to ANSI C29.11, clause 8.2.1.3 and 8.2.1.4. The flashover voltage was obtained by increasing the voltage continuously from zero up to flashover. The average of five flashovers was calculated.

All measured voltages were corrected to the standard reference atmospheric conditions according to ANSI C29.11, clause 8.2.1.5.

The test arrangement was set up in compliance with ANSI C29.11, clause 8.2.1.2 and 8.1 (see Figure 6).

Testing and measuring equipment:

synchronous generator BEZ Bratislava 6 kV, 1 300 kVA

test transformer TuR Dresden 5,7/1200 kV, 1500 kVA, serial No. 884469

capacitive divider TuR Dresden 1200 kV, 150 pF, type WMC 160/1200, serial No. 884470

universal voltmeter Haefely Trench, type DMI 551, serial No. 150505

measuring system for atmospheric conditions Comet, serial No. 10910247

tape measure 5 m, CXS, PM-241

digital stop-watch Kalenji PM-259

2.4.2 Test results

Table 4 Test results of the low-frequency dry flashover test

| | |
|---|---------------|
| Atm. conditions: | |
| barometric pressure (in Hg) | 29,29 |
| temperature of air (°F) | 59,9 |
| relative humidity (%) | 37,1 |
| Correction factors: | |
| humidity correction factor K_h | 1,130 |
| air density correction factor K_d | 1,011 |
| Flashover voltage | 390 kV |
| Measured arcing distance: 980 mm | |
| Drawing specified low-frequency dry flashover voltage: 400 kV | |

Evaluation:

Low-frequency dry flashover value was equal to or exceed 95% of the rated dry flashover value specified by drawing 400 kV, i.e. 380 kV.

Statement of conformity:

69 kV Composite insulator, SML 133 kN, drawing No. 21SM510755 Rev. A, passed the test according to requirements given in ANSI C29.12, clause 9.1.

3 LIST OF SYMBOLS

| | |
|----------------------------|--|
| RIV | radio influence voltage (μV) |
| b | barometric pressure (in Hg) |
| t | temperature of air ($^{\circ}\text{F}$) |
| RH | relative humidity (%) |
| K_h | humidity correction factor |
| K_d | air density correction factor |
| U_{pk} | maximum voltage of recorded curve (kV) |
| β' | relative overshoot (%) |
| T₁ | front time of recorded curve (μs) |
| T₂ | time to half-value of recorded curve (μs) |
| r.i. | average value of measured rainfall intensity – vertical component (mm/min) |
| conductivity | water conductivity ($\mu\text{S/cm}$) |

4 UNCERTAINTY OF MEASUREMENTS

| QUANTITY | UNCERTAINTY (k=2) | |
|----------------------------|-------------------|-------|
| Lightning impulse voltage | U_{pk} | 1,7 % |
| | T_1 | 8,0 % |
| | T_2 | 3,1 % |
| Radio interference voltage | 1,0 dB | |
| Power-frequency voltage | 1,7 % | |
| Barometric pressure | 0,5 % | |
| Temperature of air | 4,0 % | |
| Relative humidity | 6,3 % | |
| Time | 0,7 % | |
| Telescopic stick | 0,8 % | |
| Length (tape measure) | 1,6 % | |
| Rainfall intensity | 10 % | |
| Conductivity | 5,0 % | |

The reported expanded uncertainty of measurement is stated as the standard uncertainty of measurement multiplied by the coverage factor $k = 2$, which for a Normal (Gaussian) distribution corresponds to a coverage probability of approximately 95 %. Details related to the statement of conformity when applied are given in a price quotation submitted to a customer before the testing and on the website of the laboratory.

5 PRODUCT DRAWING




Figure 1
69 kV Composite insulator, SML 133 kN, drawing No. 21SM510755 Rev. A

6 TEST SETUP PHOTOS



Figure 2
Test arrangement for RIV and corona tests



Figure 3
Test arrangement for RIV and corona tests



Figure 4
Test arrangement and flashover under the critical impulse flashover test





Figure 5
Test arrangement and flashover under the low-frequency wet flashover test



Figure 6
Test arrangement and flashover under the low-frequency dry flashover test

7 GRAPHS



Graph 1
Representative wave shape of the lightning impulse 1,2/50 μs

- end of test report -



Testing laboratory No. 1595
accredited by ČIA
according to ČSN EN ISO/IEC 17025: 2018



Bohuslavice 123
798 56 Bohuslavice
IČO 29211506
DIČ CZ29211506

laboratory manager : Eva Kovářová
tel.: + 420 582 383 680

kovarova@testpolymer.cz
www.testpolymer.cz

Test report No. 59/2022/EN


| | |
|--------------------------------|--|
| Customer: | EGU - HV Laboratory a.s., Podnikatelská 267, 190 11 Praha 9, Běchovice |
| | Company ID: 25634330, Tax ID: CZ25634330 |
| Customer's order: | 6/11788/2022 |
| Application form: | 2200223 |
| Tested material: | HTV silicone material |
| Detailed description: | Manufacturer: Jiangsu Shemar Electric Co., Ltd. |
| Form of material: | test specimens - sampled and delivered by customer |
| Preparation of samples: | test specimens supplied by customer |
| Date of receipt of the sample: | 10.1.2022 |

| Tests | Test specifications |
|---|---|
| Fire hazard testing - horizontal and vertical flame tests | UL 94: 2013 revision 05/2021 ČSN EN 60695-11-10 ed.2: 2014 |

These tests were performed in accordance with the standard ČSN EN 62217 ed.2: 2013, article 9.3.4.

| | |
|-------------|--|
| Test No. 15 | Fire hazard testing - Horizontal and vertical flame tests - method A - horizontal burning test |
|-------------|--|

Photo of the position of the test specimen during the test:



Test report No. 59/2022/EN


| | | | | | |
|--|--|--------------------|---------------------------|---|------------------------------------|
| Test standard: | ČSN EN 60695-11-10 ed. 2: 2014 | | | | |
| Test equipment: | Chamber Atlas HVUL2 | | | | |
| Ignition source: | Burner with an inner diameter 9.5 mm | | | | |
| | The gas used: Methane 2.5 | | | | |
| Test conditions: | Blue flame height 20 mm, the exposure time 30s | | | | |
| | No forced ventilation was used during the test | | | | |
| | Temperature: | 22,0 - 23,0°C | | | Humidity: 48,0 - 49,0% |
| Description of the sample (sample type, the color, the location in the product, the number of samples tested): | Test specimens of grey color 125x13x3mm, 3 pieces | | | | |
| Conditioning of samples: | 48 hours at 23±2°C and 50±5% relative humidity | | | | |
| Conditioning of cotton indicator: | 24 hours in desiccator 23±2°C | | | | |
| Deviations from the standard: | no | | | | |
| Test progress: | After removing the ignition flame, the test specimens do not burn. The flame did not exceed the 25 mm mark. A support fixture was used during the test due to the bending of the test specimens. | | | | |
| Test specimen No.1 | burning stopped before 25 mm | | | | |
| Test specimen No.2 | burning stopped before 25 mm | | | | |
| Test specimen No.3 | burning stopped before 25 mm | | | | |
| | | | | | |
| No. of test specimen | Damaged length L (mm) | Burning time t (s) | Linear burn rate (mm/min) | Linear burn rate average value (mm/min) | Sample standard deviation (mm/min) |
| 1 | 0 | 0 | 0 | 0 | 0 |
| 2 | 0 | 0 | 0 | | |
| 3 | 0 | 0 | 0 | | |
| | | | | | |
| Statement of conformity to specifications - classification | <p>Measured results (burning rate, damaged length) on tested three samples meet all requirements for classification</p> <p>HB according to article 8.4 ČSN EN 60695-11-10 ed.2</p> <p>This statement of conformity to specifications is given in the sense of the shared risk decision rule; without including measurement uncertainty.</p> | | | | |
| | | | | | |
| Tested and evaluated by: | Ing. Lukáš Navrátil | | | Date: | 13.1.2022 |

Test report No. 59/2022/EN

Test No. 15

Fire hazard testing - horizontal and vertical flame tests - method B - vertical burning test

Photo of the position of the test specimen during the test:



| | | |
|--|---|------------------------|
| Test standard: | ČSN EN 60695-11-10 ed. 2: 2014 | |
| Test equipment: | Chamber Atlas HVUL2 | |
| Ignition source: | Burner with an inner diameter 9.5 mm | |
| | The gas used: Methane 2.5 | |
| Test conditions: | Blue flame height 20 mm, the exposure time 2 x 10s | |
| | No forced ventilation was used during the test | |
| | Temperature: 22,0 - 23,0°C | Humidity: 48,0 - 49,0% |
| Description of the sample (sample type, the color, the location in the product, the number of samples tested): | Test specimens of grey color 125x13x3mm, 10 pieces | |
| Conditioning of samples: | 5 pieces - 48 hours in the climate chamber at 23±2°C and 50±5% relative humidity; 5 pieces -168 ±2 hours in the hot air oven at 70±2°C and cooled in desiccator min. 4 hours at room temperature | |
| Conditioning of cotton indicator: | 24 hours in desiccator 23±2°C | |
| Deviations from the standard: | Not detected | |
| Test progress: | The test specimens do not burn after the first or after the second application of the flame. The material does not drip or ignite absorbent cotton. | |

Test report No. 59/2022/EN

| No. of test specimen: | Afterflame time after the first flame application t_1 (s) | Afterflame time after the second flame application t_2 (s) | Afterflame plus afterglow time after the second flame application t_2+t_3 (s) | Afterflame up to the holding clamp: YES - NO | Flaming particles or drops: YES - NO | Cotton indicator ignited by flaming particles or drops: YES - NO |
|--|---|--|---|---|---|---|
| Specimens conditioned in climate chamber | | | | | | |
| 1 | 0 | 0 | 0 | NO | NO | NO |
| 2 | 0 | 0 | 0 | NO | NO | NO |
| 3 | 0 | 0 | 0 | NO | NO | NO |
| 4 | 0 | 0 | 0 | NO | NO | NO |
| 5 | 0 | 0 | 0 | NO | NO | NO |
| Specimens conditioned in hot air oven | | | | | | |
| 1 | 0 | 0 | 0 | NO | NO | NO |
| 2 | 0 | 0 | 0 | NO | NO | NO |
| 3 | 0 | 0 | 0 | NO | NO | NO |
| 4 | 0 | 0 | 0 | NO | NO | NO |
| 5 | 0 | 0 | 0 | NO | NO | NO |
| Statement of conformity to specifications - classification | | The measured results (burning and afterglow times and the condition of the cotton indicators) on the ten samples tested meet all the requirements for classification V-0 according to article 9.4 ČSN EN 60695-11-10 ed. 2. | | | | |
| | | This statement of conformity to specifications is given in the sense of the shared risk decision rule; without including measurement uncertainty. | | | | |
| Tested and evaluated by: | | Ing. Lukáš Navrátil | | Date: 13.1.2022, 18.1.2022 | | |

Declaration:

Test results relates only to the test subject and refer to the sample as received
Laboratory is not responsible for sampling and specimen preparations done by customer.
Without the written consent of the Head of Laboratory, the protocol cannot be reproduced other than the entire.
All results are metrologically traceable.

Test report was created by:

Jana Trbušková
Jana Trbušková
Chief laboratory technician

Test report was approved by:

Eva Kovářová
Eva Kovářová
Laboratory manager

In Bohuslavice:

19.1.2022

End of test report



SYNPO, akciová společnost
S. K. Neumanna 1316
532 07 Pardubice - Zelené Předměstí
The Czech Republic

Department of Evaluation and Testing
Testing Laboratory No. 1105.2 accredited by CAI according to ČSN EN ISO/IEC 17025:2018

TEST REPORT T 375/005

| | |
|--|--|
| Name and contact information of the customer | EGU – HV Laboratory a.s. Podnikatelská 267, 190 11 Praha 9 – Běchovice The Czech Republic |
| Test item(s) | Manufacturer: Jiangsu Shemar Electric Co., Ltd. Address : No. 66, Haiwei Road, Sutong Science and Technology Industrial Park, Nantong City, Jiangsu 226017, China Type : HTV |
| Test procedure/method | Test No. 35: Exposure to laboratory light – Xenon - arc lamps - ČSN EN ISO 4892-2 Test No. 1 : Determination of the degree of degradation of coatings APP 1 (ČSN EN ISO 4628 -1, 4, 5) Test No. 33 : Surface roughness measurement (Ra, Rz, Ry, Rq) (ČSN EN ISO 4287, ČSN EN ISO 4288) |
| Date of receipt of item(s) | January 7, 2022 |
| Internal laboratory number | 22 0065 |
| Date of the test | January 7, 2022– February 22, 2022 |
| Tested by | Gabriela Štěpánková |
| The report made by | Gabriela Štěpánková, Ondřej Janča |

This report contains 6 pages and 1 annex.



Digitálně
podepsal Ing.
Vladimír
Špaček, CSc.
Dr. Vladimír Špaček
Head of testing laboratory

In Pardubice on March 29, 2022

The test results relate only to the test item(s) as received.
This test report by itself in no way constitutes or implies product approval by any other body.
The test report shall not be reproduced except in full, without written approval of the laboratory.

TEST REPORT T 375/005

Page/Total pages: 2/6

Annexes: 1



DESCRIPTION OF THE TEST ITEM

| | |
|---|---|
| Test item: | Manufacturer: Jiangsu Shemar Electric Co., Ltd. Address : No. 66, Haiwei Road, Sutong Science and Technology Industrial Park, Nantong City, Jiangsu 226017, China Type : HTV |
| Data delivered by the customer ¹ : | - |
| Internal lab number: | 22 0065 |

¹The laboratory is not responsible for the data delivered by customer.

FURTHER SPECIFICATION OF THE TEST PERFORMANCE

The samples of testing were received from the contractor and submitted to the test without any treatment of surface protection or heat storage.

Test No. 35: Exposure to laboratory light – Xenon - arc lamps

Testing device: Q-SUN Xe-3HS (Q-Lab, GB), Xenon lamps with irradiation energy 0,51 W/m²/nm at 340 nm (60 W/m²/nm for TUV). Filtres used – Q-Daylight. Used IBP placed horizontally at the site of sample exposure was fasten by anticorrosion screw. Irradiation intensity was calibrated by radiometer with zone detector of 340 nm (or TUV).

Description of exposure cycle:

Exposure cycle A1: 102 min of irradiance phase with BP temperature (65 ± 3) °C, chamber temperature (38 ± 3) °C with RH (50 ± 10) %. Spray phase (front spraying) of 18 min. (according to the requirements of article 9. 3. 2 of IEC 62217 (2012) - cycle 1 with 8 hours dark period). Both phases with irradiation energy 0,51 W/m²/nm at 340 nm (60 W/m²/nm for TUV). Pause: 4.2. – 8.2.2022. The test samples were putted in testing area and the position of samples during the test was not changed.

Test No. 33: Surface roughness measurement

Test was performed according to ČSN EN ISO 4288 - Geometrical product specifications (GPS) - Surface texture: Profile method – Rules and procedures for the assessment of surface texture. Parameters of surface texture were measured according to ČSN EN ISO 4287- Geometrical product specifications (GPS) - Surface texture: Profile method - Terms, definitions and surface texture parameters.

Testing device: SURFTEST SJ-201 (Mitutoyo, Ltd., Japan).

Ra - arithmetical mean deviation of the assessed profile (roughness)

Rz - maximum height of profile (roughness).

Measurements were performed six times on each sample.

Measurement conditions: basic roughness length 0,8mm

SYNPO, akciová společnost, S. K. Neumanna 1316, 532 07 Pardubice – Zelené Předměstí, Czech Republic
Department of Evaluation and Testing, Testing Laboratory No. 1105.2 accredited by CAI according to ČSN EN ISO/IEC 17025:2018

TEST REPORT T 375/005

Page/Total pages: 3/6

Annexes: 1



DESCRIPTION OF THE TEST ITEM

| | |
|---|---|
| Test item: | Manufacturer: Jiangsu Shemar Electric Co., Ltd. Address : No. 66, Haiwei Road, Sutong Science and Technology Industrial Park, Nantong City, Jiangsu 226017, China Type : HTV |
| Data delivered by the customer ¹ : | - |
| Internal lab number: | 22 0065 |

¹The laboratory is not responsible for the data delivered by customer.

APP 1 - Determination of the degree of degradation of coatings

The evaluation of surface failure (defects) was performed according standard ČSN EN ISO 4628 Paints and varnishes – Evaluation of degradation of coatings – Designation of quantity and size of defects, and of intensity of uniform changes in appearance; Part 1: General introduction and designation system; Part 4: Assessment of degree of cracking; Part 5: Assessment of degree of flaking

Lighting used in the evaluation of defect on the surface finish: the fluorescent tube, standard observation: the observation angle 0° / light incidence of angle 45°.

TEST REPORT T 375/005

Page/Total pages: 4/6

Annexes: 1



VISUAL EVALUATION OF SURFACE DEFECTS ACCORDING TO ČSN EN ISO 4628 DURING THE EXPOSURE AFTER XENON TEST ACCORDING TO ČSN EN ISO 4892-2

(January 7, 2022 – February 22, 2022)

| Sample name | Internal Lab Number | Surface failure | Cracking | Flaking |
|-------------|---------------------|-------------------|-------------------|-------------------|
| | | ČSN EN ISO 4628-1 | ČSN EN ISO 4628-4 | ČSN EN ISO 4628-5 |
| | | degree + verbal | degree | degree |

250 hours

| | | | | |
|-----|-----------|-----------------------------|---------------|---------------|
| HTV | 22 0065/1 | 0, no visual changes | 0 (S0) | 0 (S0) |
| | 22 0065/2 | 0, no visual changes | 0 (S0) | 0 (S0) |
| | 22 0065/3 | 0, no visual changes | 0 (S0) | 0 (S0) |

500 hours

| | | | | |
|-----|-----------|-----------------------------|---------------|---------------|
| HTV | 22 0065/1 | 0, no visual changes | 0 (S0) | 0 (S0) |
| | 22 0065/2 | 0, no visual changes | 0 (S0) | 0 (S0) |
| | 22 0065/3 | 0, no visual changes | 0 (S0) | 0 (S0) |

750 hours

| | | | | |
|-----|-----------|-----------------------------|---------------|---------------|
| HTV | 22 0065/1 | 0, no visual changes | 0 (S0) | 0 (S0) |
| | 22 0065/2 | 0, no visual changes | 0 (S0) | 0 (S0) |
| | 22 0065/3 | 0, no visual changes | 0 (S0) | 0 (S0) |

1000 hours

| | | | | |
|-----|-----------|-----------------------------|---------------|---------------|
| HTV | 22 0065/1 | 0, no visual changes | 0 (S0) | 0 (S0) |
| | 22 0065/2 | 0, no visual changes | 0 (S0) | 0 (S0) |
| | 22 0065/3 | 0, no visual changes | 0 (S0) | 0 (S0) |

TEST REPORT T 375/005

Page/Total pages: 5/6

Annexes: 1



MEASUREMENT OF SURFACE ROUGHNESS ACCORDING TO ČSN EN ISO 4287, 4288

(January 7, 2022 – February 22, 2022)

| Sample name | Internal Lab Number | Arithmetical mean deviation of the assessed roughness <u>R_a</u> | | | Maximum height of profile (roughness) <u>R_z</u> | | |
|-------------|---------------------|--|------|------|--|------|------|
| | | Measuring range [μm] | | | Measuring range [μm] | | |
| | | Mean | Max. | Min. | Mean | Max. | Min. |

Before exposure

| | | | | | | | |
|------------|-----------|-------------|------|------|-------------|------|------|
| HTV | 22 0065/1 | 0,70 | 0,76 | 0,65 | 5,00 | 5,42 | 4,56 |
| | 22 0065/2 | 0,72 | 0,77 | 0,68 | 5,35 | 6,18 | 4,89 |
| | 22 0065/3 | 0,71 | 0,75 | 0,66 | 5,20 | 5,71 | 4,55 |

250 hours

| | | | | | | | |
|------------|-----------|-------------|------|------|-------------|------|------|
| HTV | 22 0065/1 | 0,70 | 0,77 | 0,65 | 5,03 | 5,47 | 4,57 |
| | 22 0065/2 | 0,74 | 0,77 | 0,70 | 5,61 | 6,23 | 5,04 |
| | 22 0065/3 | 0,73 | 0,79 | 0,70 | 5,36 | 5,78 | 5,04 |

500 hours

| | | | | | | | |
|------------|-----------|-------------|------|------|-------------|------|------|
| HTV | 22 0065/1 | 0,73 | 0,77 | 0,70 | 5,26 | 5,50 | 4,93 |
| | 22 0065/2 | 0,76 | 0,79 | 0,74 | 5,35 | 5,82 | 4,98 |
| | 22 0065/3 | 0,77 | 0,80 | 0,75 | 5,34 | 5,96 | 4,98 |

750 hours

| | | | | | | | |
|------------|-----------|-------------|------|------|-------------|------|------|
| HTV | 22 0065/1 | 0,76 | 0,80 | 0,74 | 5,54 | 6,15 | 5,23 |
| | 22 0065/2 | 0,77 | 0,79 | 0,75 | 5,35 | 5,63 | 5,11 |
| | 22 0065/3 | 0,77 | 0,80 | 0,74 | 5,62 | 5,96 | 5,32 |

1000 hours

| | | | | | | | |
|------------|-----------|-------------|------|------|-------------|------|------|
| HTV | 22 0065/1 | 0,76 | 0,78 | 0,74 | 5,75 | 6,20 | 5,11 |
| | 22 0065/2 | 0,77 | 0,80 | 0,74 | 5,85 | 6,23 | 5,36 |
| | 22 0065/3 | 0,79 | 0,82 | 0,75 | 6,01 | 6,56 | 5,59 |

SYNPO, akciová společnost, S. K. Neumanna 1316, 532 07 Pardubice – Zelené Předměstí, Czech Republic
 Department of Evaluation and Testing, Testing Laboratory No. 1105.2 accredited by CAI according to ČSN EN ISO/IEC 17025:2018

TEST REPORT T 375/005

Page/Total pages: 6/6

Annexes: 1



DESCRIPTION OF THE TEST ITEM

| | |
|---|---|
| Test item: | Manufacturer: Jiangsu Shemar Electric Co., Ltd. Address : No. 66, Haiwei Road, Sutong Science and Technology Industrial Park, Nantong City, Jiangsu 226017, China Type : HTV |
| Data delivered by the customer ¹ : | - |
| Internal lab number: | 22 0065 |

¹The laboratory is not responsible for the data delivered by customer.

Statement of conformity

The laboratory uses a binary decision rule according to ILAC-G08: 09/2019, article 4.2.1

| Test items | Prescribed test | Parameter no cracks or raised parts | Fulfillment of parameters |
|------------|---------------------|--|---------------------------|
| | | result according to IEC 62217 (2012), clause 9.3.2 | |
| HTV | ČSN EN ISO 4892 - 2 | no cracks or raised parts | <u>Yes</u> |

- End-

SYNPO, akciová společnost, S. K. Neumanna 1316, 532 07 Pardubice – Zelené Předměstí, Czech Republic
Department of Evaluation and Testing, Testing Laboratory No. 1105.2 accredited by CAI according to ČSN EN ISO/IEC 17025:2018

TEST REPORT T 375/005

Annexes: 1/1




DESCRIPTION OF THE TEST ITEM

| | |
|---|---|
| Test item: | Manufacturer: Jiangsu Shemar Electric Co., Ltd. Address : No. 66, Haiwei Road, Sutong Science and Technology Industrial Park, Nantong City, Jiangsu 226017, China Type : HTV |
| Data delivered by the customer ¹ : | - |
| Internal lab number: | 22 0065 |


¹The laboratory is not responsible for the data delivered by customer.

THE PHOTOS OF TEST SAMPLES AFTER 1000 HOURS OF EXPOSURE UNDER XENON LAMPS ACCORDING TO ČSN EN ISO 4892-2

1



2



Pic 1 : Exposure after 1000hrs (top face)

Pic 2 : Exposure after 1000hrs (lower face)