



EGU HV LABORATORY

Accredited testing laboratory No.: 1029

Accredited by Czech Accreditation Institute
according to ČSN EN ISO/IEC 17025:2018

TEST REPORT No.: 11788/K/21

CUSTOMER:

Jiangsu Shemar Electric Co., Ltd.
66 Haiwei Road
226 017 Nantong, Jiangsu
China



TEST OBJECT:

345 kV Composite insulator

TYPE SPECIFICATION: SML 222 kN

TEST STANDARDS:

CSA C411.4-16, CSA C411.1-16,
IEC 60383-1 Ed.4:1993, NEMA 107:2016



Michal Novotný
Test engineer



Marek Brosch
Head of
EGU HV LABORATORY



Jan Lachman, Ph.D.
Director of
EGU - HV Laboratory a. s.

Test report is confidential and must not be circulated or transferred to any third party without written approval of the customer. Test results relate only to the tests given in presented report and do not substitute any other documents. The report shall not be reproduced except in full without written approval of the testing laboratory. EGU HV Laboratory doesn't perform sampling as test objects and relevant data are supplied to EGU HV Laboratory by a customer. All tests were performed by EGU HV Laboratory at its registered office address if not specified else in this test report. The results apply to the sample as received. EGU HV Laboratory doesn't accept any kind of information provided by a customer that could affect validity of test results.

TEST REPORT**No.: 11788/K/21****TEST OBJECT:** 345 kV Composite insulator**TYPE SPECIFICATION:** SML 222 kN**DRAWING No.:** 21SM510759 Rev. B**MANUFACTURER:** Jiangsu Shemar Electric Co., Ltd.**DATE OF DELIVERY:** 2021-12-09**DATE OF TESTS:** From 2022-02-28 till 2022-03-03**ORDER No.:** Contract 23/21**TESTS WITNESSED BY:** N/A

TABLE OF CONTENTS

1	TEST SUMMARY	4
2	TESTS PERFORMED.....	5
2.1	Corona test	5
2.1.1	Test procedure	5
2.1.2	Test results.....	6
2.2	Critical impulse flashover test	8
2.2.1	Test procedure	8
2.2.2	Test results.....	9
2.3	Wet power frequency voltage flashover test	10
2.3.1	Test procedure	10
2.3.2	Test results.....	11
3	LIST OF SYMBOLS	12
4	UNCERTAINTY OF MEASUREMENTS	13
5	PRODUCT DRAWING.....	14
6	TEST SETUP PHOTOS	15
7	GRAPHS.....	18

1 TEST SUMMARY

Test title	Test standards	Test result
Corona test	CSA C411.4-16, clause 6.4.4	Passed
Critical impulse flashover test	CSA C411.4-16, clause 6.2 CSA C411.1-16, clause 6.5.1 to 6.5.3	Passed
Wet power frequency voltage flashover test	CSA C411.4-16, clause 6.3 CSA C411.1-16, clause 6.4	No criteria

2 TESTS PERFORMED

2.1 Corona test

2.1.1 Test procedure

Date of test: 2022-02-28

The test was carried out according to CSA C411.4-16, clause 6.4.4 and customer requirements. The test was performed on one composite insulator assembly, including grading rings, serial No. 2111161518.

After the test room was thoroughly darkened the voltage above corona point was applied and held for 5 minutes. The voltage was then reduced until corona disappeared from the test object to measure the corona extinction voltage. This procedure was three (3) times repeated. Field glasses were used for the observation of the corona. Measured extinction voltages are shown in Table 2.

The test arrangement was set up according to CSA C411.4-16, clause 6.4.2.2 (see Figure 2). The bundle of double conductors with spacing 457 mm was simulated using an aluminium tube of 14 m length and 30 mm diameter. Both ends of the tubes were terminated with corona shielding spheres (screening electrode) with a diameter of 300 mm. Bundle of conductors was at a height of 5,1 m above the ground.

The exact line configuration (conductor surface voltage gradient E_2) was not known in time of the test. The client specified test voltage (minimum corona extinction voltage) as 120% of maximum design phase-to ground service voltage i.e. $V_T = 1,2 \times 362/\sqrt{3} = 251$ kV.

The test object at the specified test voltage is shown in Figure 4. The corona discharges are shown in Figure 5.

Radio interference voltage RIV was measured according to NEMA 107. RIV (expressed in decibels relative to 1 μ V across 150 Ω) was measured at the frequency of 1,0 MHz in compliance with the circuit diagram in Figure 3-3a of NEMA 107, Section 3.

The circuit RIV factor was 0,42.

Measured RIV values are shown in Table 1.

Testing and measuring equipment:

coupling capacitance, 1 000 pF, 800 kV, serial No. 11100108.10.1

measuring impedance Power Diagnostix, NEMA 150 Ω , type CIT4M/V8 μ 0/RIV, serial No. 12533

test transformer TuR Dresden 5,7/1 200 kV, 1 500 kVA

inductive regulator ČKD Praha 6/ 0 - 3 kV, 50 kVA

capacitive divider TuR Dresden 1 200 kV, 150 pF, type WMC 160/1200, serial No. 884470

universal voltmeter Haefely Trench, type DMI 551, serial No. 150505

RIV meter - measuring receiver Power Diagnostix, type RIV meter, serial No. 035

calibrator Power Diagnostix, type CAL3B, serial No. 3014

measuring system for atmospheric condition COMET, serial No. 10910247

digital stop-watch Kalenji, PM-259

field glasses Nikon Action EX 7x50, serial.No. 320695

measuring telescopic stick 5m, type BMI, serial No. 102

2.1.2 Test results

Table 1 Test results of the RIV test

U_m (kV)	362		
Atm. conditions			
p (kPa)	100,4		
t (°C)	15,4		
RH (%)	30,5		
Test voltage (kV)	RIV ↓ (μV)	RIV ↑ (μV)	RIV ↓ (μV)
326	44 668	44 668	44 668
301	35 481	35 481	35 481
276	316	316	316
251	50	50	50
226	32	32	32
201	22	22	22
176	22	22	22
151	22	22	22
126	22	22	22
0	22	22	22

Table 2 Test results of the corona test

U_m (kV)	362
Atm. conditions	
p (kPa)	100,4
t (°C)	15,4
RH (%)	30,5
Measurement No.	U_e (kV)
1	281
2	279
3	281
Average value	280
Location of corona	Corona ring
Criteria: U _e > 251 kV	

Evaluation:

Measured corona extinction voltages U_e were greater than the specified minimum corona extinction voltage of 251 kV.

Statement of conformity:

345 kV Composite insulator, SML 222 kN, drawing No. 21SM510759 Rev. B, passed the test according to requirements given in CSA C411.4-16, clause 6.4.4.

2.2 Critical impulse flashover test

2.2.1 Test procedure

Date of test: 2022-03-01

The test was carried out according to CSA C411.4-16, clause 6.2 and CSA C411.1, clause 6.5.1 to 6.5.3.

The tests were performed on three insulators:

No. 1, serial No. 2111161520,

No. 2, serial No. 2111161517,

No. 3, serial No. 2111161518.

The critical impulse voltages of both polarities were determined by the up and down method with 30 impulses according to CSA C411.1-16, clause 6.5.3.

All measured voltages were corrected to the standard reference atmospheric conditions according to CSA C411.1-16, clause 6.2.5 and 6.2.6.

The representative wave shape of the lightning impulse 1,2/50 μ s is given Graph 1.

The test arrangement was set up in compliance with IEC 60383-1, clause 34 (see Figure 6).

Testing and measuring devices:

impulse generator TuR 3,0 MV, serial No. 1543

capacitive divider TuR Dresden, type KOIS-3-500, serial No. 32373

measuring system DiAS 733, serial No. 173990

tape measure 5 m, CXS, PM-241

measuring system for atmospheric condition COMET, serial No. 10910247

2.2.2 Test results

Table 3 Test results of the critical impulse flashover test

Test sample No.	1		2		3	
Impulse polarity	+	–	+	–	+	–
Atm. conditions:						
air pressure (kPa)	100,3	100,3	100,3	100,3	100,3	100,3
air temperature (°C)	15,6	15,6	15,6	15,6	15,6	15,6
relative humidity (%)	31,9	31,9	31,9	31,9	31,9	31,9
Correction factors:						
air density correction factor k ₁	1,005	1,005	1,005	1,005	1,005	1,005
humidity correction factor k ₂	0,932	0,948	0,933	0,948	0,932	0,947
atmospheric correction factor K _t	0,937	0,953	0,938	0,953	0,937	0,952
Critical impulse flashover voltage (kV)	1 476	1 599	1 488	1 596	1 482	1 587
Polarity	+			-		
Average critical impulse flashover value of the three insulators (kV)	1 482			1 594		
Measured arcing distance: 2 470 mm						
Drawing specified critical impulse flashover voltage: 1 410 kV						
CSA C411.-16, Table 2 specified critical impulse flashover voltage: 1 410 kV						

Evaluation:

The average critical impulse flashover value of the three insulators was equal to or exceed 95% of the rated critical impulse flashover value specified by CSA C411.4-16, Table 2 and drawing 1 410 kV, i.e. 1 340 kV.

Statement of conformity:

345 kV Composite insulator, SML 222 kN, drawing No. 21SM510759 Rev. B, passed the test according to requirements given in CSA C411.4-16, clause 6.2. and client requirements.

2.3 Wet power frequency voltage flashover test

2.3.1 Test procedure

Date of test: 2022-03-03

The test was carried out according to CSA C411.4-16, clause 6.3 and CSA C411.1-16, clause 6.4.

The tests were performed on three insulators:

No. 1, serial No. 2111161520,

No. 2, serial No. 2111161517,

No. 3, serial No. 2111161518.

Characteristics of the artificial rain and precipitation method was in accordance with the CSA C411.1-16, clause 6.4.3.

The wet power-frequency flashover voltage test was performed according to CSA C411.1-16, clause 6.4.4. The flashover voltage was obtained by increasing the voltage continuously from zero up to flashover. The average of five flashovers was calculated.

All measured voltages were corrected to the standard reference atmospheric conditions according to CSA C411.1-16, clause 6.2.5 and 6.2.6.

The test arrangement was set up in compliance with IEC 60383-1, clause 34 (see Figure 7).

Testing and measuring equipment:

synchronous generator BEZ Bratislava 6 kV, 1 300 kVA, 50 Hz

test transformer TuR Dresden 5,7/1200 kV, 1500 kVA, serial No. 884469

capacitive divider TuR Dresden 1200 kV, 150 pF, type WMC 160/1200, serial No. 884470

universal voltmeter Haefely Trench, type DMI 551, serial No. 150505

measuring system for atmospheric conditions Comet, serial No. 10910247

tape measure 5 m, CXS, PM-241

digital stop-watch Kalenji PM-259

conductivity meter WTW Cond 3310, serial No. 10410891

plastic measuring cylinder 50ml, identification No. 1/153/14 & 2/153/14

2.3.2 Test results

Table 4 Test results of the wet power frequency flashover voltage test

Test sample No.	1	2	3
Atm. conditions:			
air pressure (kPa)	98,6	98,6	98,6
air temperature (°C)	15,7	15,7	15,7
relative humidity (%)	48,0	48,0	48,0
Rain parameters:			
vertical (mm/min)	1,3	1,3	1,3
horizontal (mm/min)	1,1	1,1	1,1
Conductivity (µS/cm)	105	105	105
Correction factors:			
air density correction factor k ₁	0,990	0,990	0,989
humidity correction factor k ₂	1,000	1,000	1,000
atmospheric correction factor K _t	0,990	0,990	0,989
Flashover voltage	759 kV	766 kV	780 kV
The average wet flashover voltage of the three insulators	768 kV		
Measured arcing distance: 2 470 mm			
Drawing specified wet power frequency flashover voltage: 750 kV			

3 LIST OF SYMBOLS

RIV	radio interference voltage (μV)
V_t	test voltage specified by client (kV)
U_m	maximum design phase-to-phase service voltage
U_e	extinction corona voltage (kV), corresponding to actual atmosphere
p	air pressure (kPa)
t	air temperature ($^{\circ}\text{C}$)
RH	relative humidity (%)
k₁	air density correction factor
k₂	humidity correction factor
K_t	atmospheric correction factor
U_{pk}	maximum voltage of recorded curve (kV)
T₁	front time of recorded curve (μs)
T₂	time to half-value of recorded curve (μs)
vertical c.	average value of rainfall intensity – vertical component (mm/min)
horizontal c.	average value of rainfall intensity – horizontal component (mm/min)
conductivity	water conductivity ($\mu\text{S/cm}$)

4 UNCERTAINTY OF MEASUREMENTS

QUANTITY	UNCERTAINTY (k=2)	
Lightning impulse voltage	U_{pk}	2,4 %
	T_1	6,5 %
	T_2	4,2 %
Radio interference voltage	1,0 dB	
Power-frequency voltage	1,7 %	
Air pressure	0,5 %	
Temperature	4,0 %	
Relative humidity	6,3 %	
Time	0,7 %	
Telescopic stick	0,8 %	
Length (tape measure)	1,6 %	
Rainfall intensity	10 %	
Conductivity	5,0 %	

The reported expanded uncertainty of measurement is stated as the standard uncertainty of measurement multiplied by the coverage factor $k = 2$, which for a Normal (Gaussian) distribution corresponds to a coverage probability of approximately 95 %. Details related to the statement of conformity when applied are given in a price quotation submitted to a customer before the testing and on the website of the laboratory.

5 PRODUCT DRAWING




Figure 1
345 kV Composite insulator, SML 222 kN, drawing No. 21SM510759 Rev. B

6 TEST SETUP PHOTOS



Figure 2
Test arrangement for RIV and corona tests



Figure 3
Test arrangement for RIV and corona tests



Figure 4
Test object at the test voltage of 251 kV – no positive corona



Figure 5
Test object at the test voltage of 326 kV



Figure 6
Test arrangement and flashover under the critical impulse flashover test





Figure 7
Test arrangement and flashover under the wet power frequency voltage flashover test


7 GRAPHS

COMPOSITE INSULATOR
RATED VOLTAGE: 345 KV
 3/1/2022 12:18:44 PM



No. 2
 LI full
 Upk : 1.380 MV
 T1 : 1.289 us
 T2 : 46.764 us

COMPOSITE INSULATOR
RATED VOLTAGE: 345 KV
 3/1/2022 12:46:14 PM



No. 5
 LI full
 Upk : -1.478 MV
 T1 : 1.152 us
 T2 : 46.639 us

Graph 1
Representative wave shape of the lightning impulse 1,2/50 μ s

- end of test report -



Testing laboratory No. 1595
accredited by ČIA
according to ČSN EN ISO/IEC 17025: 2018



Bohuslavice 123
798 56 Bohuslavice
IČO 29211506
DIČ CZ29211506

laboratory manager : Eva Kovářová
tel.: + 420 582 383 680

kovarova@testpolymer.cz
www.testpolymer.cz

Test report No. 59/2022/EN


Customer:	EGU - HV Laboratory a.s., Podnikatelská 267, 190 11 Praha 9, Běchovice
	Company ID: 25634330, Tax ID: CZ25634330
Customer's order:	6/11788/2022
Application form:	2200223
Tested material:	HTV silicone material
Detailed description:	Manufacturer: Jiangsu Shemar Electric Co., Ltd.
Form of material:	test specimens - sampled and delivered by customer
Preparation of samples:	test specimens supplied by customer
Date of receipt of the sample:	10.1.2022

Tests	Test specifications
Fire hazard testing - horizontal and vertical flame tests	UL 94: 2013 revision 05/2021 ČSN EN 60695-11-10 ed.2: 2014

These tests were performed in accordance with the standard ČSN EN 62217 ed.2: 2013, article 9.3.4.

Test No. 15	Fire hazard testing - Horizontal and vertical flame tests - method A - horizontal burning test
-------------	--

Photo of the position of the test specimen during the test:



Test report No. 59/2022/EN


Test standard:	ČSN EN 60695-11-10 ed. 2: 2014				
Test equipment:	Chamber Atlas HVUL2				
Ignition source:	Burner with an inner diameter 9.5 mm				
	The gas used: Methane 2.5				
Test conditions:	Blue flame height 20 mm, the exposure time 30s				
	No forced ventilation was used during the test				
	Temperature:	22,0 - 23,0°C			Humidity: 48,0 - 49,0%
Description of the sample (sample type, the color, the location in the product, the number of samples tested):	Test specimens of grey color 125x13x3mm, 3 pieces				
Conditioning of samples:	48 hours at 23±2°C and 50±5% relative humidity				
Conditioning of cotton indicator:	24 hours in desiccator 23±2°C				
Deviations from the standard:	no				
Test progress:	After removing the ignition flame, the test specimens do not burn. The flame did not exceed the 25 mm mark. A support fixture was used during the test due to the bending of the test specimens.				
Test specimen No.1	burning stopped before 25 mm				
Test specimen No.2	burning stopped before 25 mm				
Test specimen No.3	burning stopped before 25 mm				
No. of test specimen	Damaged length L (mm)	Burning time t (s)	Linear burn rate (mm/min)	Linear burn rate average value (mm/min)	Sample standard deviation (mm/min)
1	0	0	0	0	0
2	0	0	0		
3	0	0	0		
Statement of conformity to specifications - classification	<p>Measured results (burning rate, damaged length) on tested three samples meet all requirements for classification</p> <p>HB according to article 8.4 ČSN EN 60695-11-10 ed.2</p> <p>This statement of conformity to specifications is given in the sense of the shared risk decision rule; without including measurement uncertainty.</p>				
Tested and evaluated by:	Ing. Lukáš Navrátil			Date:	13.1.2022

Test report No. 59/2022/EN

Test No. 15

Fire hazard testing - horizontal and vertical flame tests - method B - vertical burning test

Photo of the position of the test specimen during the test:



Test standard:	ČSN EN 60695-11-10 ed. 2: 2014	
Test equipment:	Chamber Atlas HVUL2	
Ignition source:	Burner with an inner diameter 9.5 mm	
	The gas used: Methane 2.5	
Test conditions:	Blue flame height 20 mm, the exposure time 2 x 10s	
	No forced ventilation was used during the test	
	Temperature: 22,0 - 23,0°C	Humidity: 48,0 - 49,0%
Description of the sample (sample type, the color, the location in the product, the number of samples tested):	Test specimens of grey color 125x13x3mm, 10 pieces	
Conditioning of samples:	5 pieces - 48 hours in the climate chamber at 23±2°C and 50±5% relative humidity; 5 pieces -168 ±2 hours in the hot air oven at 70±2°C and cooled in desiccator min. 4 hours at room temperature	
Conditioning of cotton indicator:	24 hours in desiccator 23±2°C	
Deviations from the standard:	Not detected	
Test progress:	The test specimens do not burn after the first or after the second application of the flame. The material does not drip or ignite absorbent cotton.	

Test report No. 59/2022/EN

No. of test specimen:	Afterflame time after the first flame application t_1 (s)	Afterflame time after the second flame application t_2 (s)	Afterflame plus afterglow time after the second flame application t_2+t_3 (s)	Afterflame up to the holding clamp: YES - NO	Flaming particles or drops: YES - NO	Cotton indicator ignited by flaming particles or drops: YES - NO
Specimens conditioned in climate chamber						
1	0	0	0	NO	NO	NO
2	0	0	0	NO	NO	NO
3	0	0	0	NO	NO	NO
4	0	0	0	NO	NO	NO
5	0	0	0	NO	NO	NO
Specimens conditioned in hot air oven						
1	0	0	0	NO	NO	NO
2	0	0	0	NO	NO	NO
3	0	0	0	NO	NO	NO
4	0	0	0	NO	NO	NO
5	0	0	0	NO	NO	NO
Statement of conformity to specifications - classification		The measured results (burning and afterglow times and the condition of the cotton indicators) on the ten samples tested meet all the requirements for classification V-0 according to article 9.4 ČSN EN 60695-11-10 ed. 2.				
		This statement of conformity to specifications is given in the sense of the shared risk decision rule; without including measurement uncertainty.				
Tested and evaluated by:		Ing. Lukáš Navrátil		Date: 13.1.2022, 18.1.2022		

Declaration:

Test results relates only to the test subject and refer to the sample as received
Laboratory is not responsible for sampling and specimen preparations done by customer.
Without the written consent of the Head of Laboratory, the protocol cannot be reproduced other than the entire.
All results are metrologically traceable.

Test report was created by:

Jana Trbušková
Jana Trbušková
Chief laboratory technician

Test report was approved by:

Eva Kovářová
Eva Kovářová
Laboratory manager

In Bohuslavice:

19.1.2022

End of test report



SYNPO, akciová společnost
S. K. Neumanna 1316
532 07 Pardubice - Zelené Předměstí
The Czech Republic

Department of Evaluation and Testing
Testing Laboratory No. 1105.2 accredited by CAI according to ČSN EN ISO/IEC 17025:2018

TEST REPORT T 375/006

Name and contact information of the customer	EGU – HV Laboratory a.s. Podnikatelská 267, 190 11 Praha 9 – Běchovice The Czech Republic
Test item(s)	Manufacturer: Jiangsu Shemar Electric Co., Ltd. Address : No. 66, Haiwei Road, Sutong Science and Technology Industrial Park, Nantong City, Jiangsu 226017, China Type : HTV
Test procedure/method	Test No. 35: Standard Practice for Xenon-Arc Exposure of Plastics Intended for Outdoor Applications ASTM D2565-16 <i>(The test was included in the flexible scope of accreditation)</i> Test No. 1 : Determination of the degree of degradation of coatings APP 1 (ČSN EN ISO 4628 -1, 4, 5) Test No. 33 : Surface roughness measurement (Ra, Rz, Ry, Rq) (ČSN EN ISO 4287, ČSN EN ISO 4288)
Date of receipt of item(s)	January 7, 2022
Internal laboratory number	22 0066
Date of the test	January 7, 2022– February 18, 2022
Tested by	Gabriela Štěpánková
The report made by	Gabriela Štěpánková, Ondřej Janča

This report contains 6 pages and 1 annex.

In Pardubice on March 29, 2022



Digitálně
podepsal Ing.
Vladimír Špaček,
CSc.

Dr. Vladimír Špaček
Head of testing laboratory

The test results relate only to the test item(s) as received.
This test report by itself in no way constitutes or implies product approval by any other body.
The test report shall not be reproduced except in full, without written approval of the laboratory.



TEST REPORT T 375/006

Page/Total pages: 2/6

Annexes: 1

DESCRIPTION OF THE TEST ITEM

Test item:	Manufacturer: Jiangsu Shemar Electric Co., Ltd. Address : No. 66, Haiwei Road, Sutong Science and Technology Industrial Park, Nantong City, Jiangsu 226017, China Type : HTV
Data delivered by the customer ¹ :	-
Internal lab number:	22 0066

¹The laboratory is not responsible for the data delivered by customer.

FURTHER SPECIFICATION OF THE TEST PERFORMANCE

The samples of testing were received from the contractor (3 pieces) and submitted to the test without any treatment of surface protection or heat storage.

Test No. 35: Standard Practice for Xenon-Arc Exposure of Plastics Intended for Outdoor Applications ASTM D2565-16

(The test was included in the flexible scope of accreditation)

Test was performed according to ASTM D2565-16

Testing device: Q-SUN Xe-3HS (Q-Lab Corporation, GB). Cycle number 1^H.

Exposure cycling: regular switching of drying period for 102 minutes at $(63 \pm 2) ^\circ\text{C}$ light followed by 18 minutes of light and front spray.

Light source: Xenon lamps with irradiance energy of $0.35 \text{ W/m}^2/\text{nm}$ at 340 nm. Used UBP placed horizontally at the site of sample exposure was fasten by anticorrosion screw.

The test samples were putted in testing area and the position of samples during the test was not changed – for measurements only.

Test No. 33: Surface roughness measurement

Test was performed according to ČSN EN ISO 4288 - Geometrical product specifications (GPS) - Surface texture: Profile method – Rules and procedures for the assessment of surface texture. Parameters of surface texture were measured according to ČSN EN ISO 4287- Geometrical product specifications (GPS) - Surface texture: Profile method - Terms, definitions and surface texture parameters.

Testing device: SURFTEST SJ-201 (Mitutoyo, Ltd., Japan).

Ra - arithmetical mean deviation of the assessed profile (roughness)

Rz - maximum height of profile (roughness).

Measurements were performed six times on each sample.

Measurement conditions: basic roughness length 0,8 mm

SYNPO, akciová společnost, S. K. Neumanna 1316, 532 07 Pardubice – Zelené Předměstí, Czech Republic
Department of Evaluation and Testing, Testing Laboratory No. 1105.2 accredited by CAI according to ČSN EN ISO/IEC 17025:2018

TEST REPORT T 375/006

Page/Total pages: 3/6

Annexes: 1



DESCRIPTION OF THE TEST ITEM

Test item:	Manufacturer: Jiangsu Shemar Electric Co., Ltd. Address : No. 66, Haiwei Road, Sutong Science and Technology Industrial Park, Nantong City, Jiangsu 226017, China Type : HTV
Data delivered by the customer ¹ :	-
Internal lab number:	22 0066

¹The laboratory is not responsible for the data delivered by customer.

APP 1 - Determination of the degree of degradation of coatings

The evaluation of surface failure (defects) was performed according standard ČSN EN ISO 4628 Paints and varnishes – Evaluation of degradation of coatings – Designation of quantity and size of defects, and of intensity of uniform changes in appearance; Part 1: General introduction and designation system; Part 4: Assessment of degree of cracking; Part 5: Assessment of degree of flaking

Lighting used in the evaluation of defect on the surface finish: the fluorescent tube, standard observation: the observation angle 0° / light incidence of angle 45°.

TEST REPORT T 375/006

Page/Total pages: 4/6

Annexes: 1



VISUAL EVALUATION OF SURFACE DEFECTS ACCORDING TO ČSN EN ISO 4628 DURING THE EXPOSURE AFTER XENON TEST ACCORDING TO ASTM D2565-16

(January 7, 2022 – February 18, 2022)

(The test was included in the flexible scope of accreditation)

Sample name	Internal Lab Number	Surface failure	Cracking	Flaking
		ČSN EN ISO 4628-1	ČSN EN ISO 4628-4	ČSN EN ISO 4628-5
		degree + verbal	degree	degree

250 hours

HTV	22 0066/1	0, no visual changes	0 (S0)	0 (S0)
	22 0066/2	0, no visual changes	0 (S0)	0 (S0)
	22 0066/3	0, no visual changes	0 (S0)	0 (S0)

500 hours

HTV	22 0066/1	0, no visual changes	0 (S0)	0 (S0)
	22 0066/2	0, no visual changes	0 (S0)	0 (S0)
	22 0066/3	0, no visual changes	0 (S0)	0 (S0)

750 hours

HTV	22 0066/1	0, no visual changes	0 (S0)	0 (S0)
	22 0066/2	0, no visual changes	0 (S0)	0 (S0)
	22 0066/3	0, no visual changes	0 (S0)	0 (S0)

1000 hours

HTV	22 0066/1	0, no visual changes	0 (S0)	0 (S0)
	22 0066/2	0, no visual changes	0 (S0)	0 (S0)
	22 0066/3	0, no visual changes	0 (S0)	0 (S0)

TEST REPORT T 375/006

Page/Total pages: 5/6

Annexes: 1



MEASUREMENT OF SURFACE ROUGHNESS ACCORDING TO ČSN EN ISO 4287, 4288

(January 7, 2022 – February 18, 2022)

Sample name	Internal Lab Number	Arithmetical mean deviation of the assessed roughness R_a			Maximum height of profile (roughness) R_z		
		Measuring range [μm]			Measuring range [μm]		
		Mean	Max.	Min.	Mean	Max.	Min.

Before exposure

HTV	22 0066/1	0,67	0,69	0,64	4,74	4,92	4,53
	22 0066/2	0,66	0,73	0,60	4,99	5,25	4,82
	22 0066/3	0,71	0,75	0,67	5,28	5,64	4,87

250 hours

HTV	22 0066/1	0,67	0,70	0,63	4,84	5,11	4,56
	22 0066/2	0,69	0,75	0,65	5,06	5,47	4,52
	22 0066/3	0,72	0,76	0,65	5,24	5,78	4,25

500 hours

HTV	22 0066/1	0,64	0,67	0,60	5,01	5,36	4,60
	22 0066/2	0,72	0,77	0,60	5,33	6,11	4,70
	22 0066/3	0,76	0,80	0,70	5,65	6,27	4,90

750 hours

HTV	22 0066/1	0,67	0,70	0,64	5,18	5,56	4,88
	22 0066/2	0,77	0,80	0,74	5,64	5,96	5,32
	22 0066/3	0,78	0,80	0,75	5,76	6,22	5,29

1000 hours

HTV	22 0066/1	0,74	0,78	0,68	5,81	6,09	5,22
	22 0066/2	0,79	0,81	0,77	5,95	6,22	5,69
	22 0066/3	0,79	0,83	0,76	6,14	6,55	5,78

SYNPO, akciová společnost, S. K. Neumanna 1316, 532 07 Pardubice – Zelené Předměstí, Czech Republic
 Department of Evaluation and Testing, Testing Laboratory No. 1105.2 accredited by CAI according to ČSN EN ISO/IEC 17025:2018

TEST REPORT T 375/006

Page/Total pages: 6/6

Annexes: 1



DESCRIPTION OF THE TEST ITEM

Test item:	Manufacturer: Jiangsu Shemar Electric Co., Ltd. Address : No. 66, Haiwei Road, Sutong Science and Technology Industrial Park, Nantong City, Jiangsu 226017, China Type : HTV
Data delivered by the customer ¹ :	-
Internal lab number:	22 0066

¹The laboratory is not responsible for the data delivered by customer.

Statement of conformity

The laboratory uses a binary decision rule according to ILAC-G08: 09/2019, article 4.2.1

Test items	Prescribed test	Parameter no surface defects such as cracks, crumbling or blisters	Fulfillment of parameters
		result according to CSA C411.4.-16 article 5.4.3	
HTV	ASTM D2565-16	no cracks, crumbling or blisters	<u>Yes</u>

-End-

SYNPO, akciová společnost, S. K. Neumanna 1316, 532 07 Pardubice – Zelené Předměstí, Czech Republic
Department of Evaluation and Testing, Testing Laboratory No. 1105.2 accredited by CAI according to ČSN EN ISO/IEC 17025:2018

TEST REPORT T 375/006

Annexes: 1/1




DESCRIPTION OF THE TEST ITEM

Test item:	Manufacturer: Jiangsu Shemar Electric Co., Ltd. Address : No. 66, Haiwei Road, Sutong Science and Technology Industrial Park, Nantong City, Jiangsu 226017, China Type : HTV
Data delivered by the customer ¹ :	-
Internal lab number:	22 0066

¹The laboratory is not responsible for the data delivered by customer.

THE PHOTOS OF TEST SAMPLES AFTER 1000 HOURS OF EXPOSURE UNDER XENON LAMPS ACCORDING TO ASTM D2565-16

(The test was included in the flexible scope of accreditation)



Pic 1 : Exposure after 1000hrs (top face)

Pic 2 : Exposure after 1000hrs (lower face)